

Contents

| | | |
|----------|---|----|
| 1 | Importance of Negative Pressure Wards | 1 |
| 1.1 | The Disaster at the Beginning of the Century | 1 |
| 1.2 | Severity of Airborne Infection | 2 |
| 1.3 | Requirement for Negative Pressure Ward | 8 |
| | References. | 11 |
| 2 | Three Misunderstandings for Design of Negative Pressure Ward | 13 |
| 2.1 | About High Negative Pressure | 13 |
| 2.1.1 | Effect of Pressure Difference | 13 |
| 2.1.2 | Ability to Control Pollution Dispersion by Pressure Difference | 16 |
| 2.2 | About Airproof Gate. | 25 |
| 2.2.1 | Effect of Entrainment by Door | 25 |
| 2.2.2 | Dynamic Characteristic of Door | 26 |
| 2.2.3 | Effect of Entrainment by Occupant | 28 |
| 2.2.4 | Effect of Temperature Difference Between Indoors and Outdoors. | 29 |
| 2.2.5 | Balance Equation of Air Change Rate with Convective Flow by Temperature Difference. | 37 |
| 2.2.6 | Relationship Between Temperature Difference and Pollutant Exchange Rate. | 39 |
| 2.3 | About Full Fresh Air | 46 |
| 2.3.1 | Outline | 46 |
| 2.3.2 | HEPA Filter and Virus Particles | 46 |
| | References. | 49 |
| 3 | Principle and Technology of Dynamic Isolation | 51 |
| 3.1 | Proper Pressure Difference for Isolation | 51 |
| 3.1.1 | Physical Significance of Pressure Difference | 52 |
| 3.1.2 | Determination of Pressure Difference | 53 |

- 3.2 Buffer Room for Isolation. 57
 - 3.2.1 Mode of Buffer Room. 58
 - 3.2.2 Isolation Coefficient of Buffer Room. 67
 - 3.2.3 Influencing Factors for Performance of Buffer Room 69
 - 3.2.4 Experimental Validation 71
 - 3.2.5 Door of Buffer Room 86
- 3.3 Airflow Isolation in Mainstream Area. 88
 - 3.3.1 Concept of Mainstream Area 88
 - 3.3.2 Function of Mainstream Area 90
- 3.4 Application of Self-circulation Air Through HEPA Filter. 92
 - 3.4.1 Application Principle of Circulation Air 92
 - 3.4.2 Function of HEPA Filter. 92
 - 3.4.3 Experimental Validation for Application of HEPA Filter
with Circulation Air 101
- References. 109
- 4 Air Distribution Design in Negative Pressure Isolation Ward 111**
 - 4.1 Fundamental Principle of Air Distribution in Negative Pressure
Isolation Ward 111
 - 4.2 Velocity Field Near Return Air Opening 112
 - 4.3 Velocity Decay Near Air Supply Outlet 114
 - 4.4 The Following Speed and the Deposition Velocity. 118
 - 4.5 Composition of Velocities and Vortex 124
 - 4.6 Position of Air Supply, Exhaust and Return Outlets in Isolation
Ward. 126
 - 4.6.1 Fundamental Principle. 126
 - 4.6.2 Related Assessment Index. 131
 - 4.6.3 Results from Numerical Simulation 132
 - 4.6.4 Experimental Validation on Performance of Opening
Position. 138
 - References. 144
- 5 Calculation of Air Change Rate 147**
 - 5.1 Outline 147
 - 5.2 Two System Modes of Isolation Ward 149
 - 5.2.1 Circulation Air System 149
 - 5.2.2 Full Fresh Air System. 150
 - 5.3 Determination of Bacterial Generation Rate Indoors. 151
 - 5.3.1 Bacterial Generation Rate from Ordinary Patients. 151
 - 5.3.2 Analysis of Bacterial Generation Rate from Respiratory
System 151
 - 5.4 Determination of Bacterial Concentration Standard Indoors 155
 - 5.4.1 Outline 155
 - 5.4.2 Standard 157

| | | |
|----------|--|------------|
| 5.5 | Calculation of Air Change Rate | 159 |
| 5.5.1 | Calculation Based on the Minimum Airborne Droplet Nuclei with Diameter 0.075 μm | 159 |
| 5.5.2 | Calculation Based on the Maximum Airborne Droplet Nuclei with Diameter from 10 μm to 1.6 μm After Evaporation. | 159 |
| 5.5.3 | Calculation Based on the Ordinary Microbial Particles Indoors | 160 |
| 5.5.4 | Calculation Based on Environmental Standard | 160 |
| | References. | 161 |
| 6 | Air Exhaust and Air Return Safely Are Necessary Conditions | 163 |
| 6.1 | Importance of Non-leakage Apparatus for Air Exhaust and Air Return | 163 |
| 6.2 | Principle of Negative Pressure and Effective Air Exhaust Device Sealed with Dynamic Air Current. | 167 |
| 6.2.1 | Structure of the Device | 167 |
| 6.2.2 | Experiment on the Device. | 168 |
| 6.2.3 | Operation Method. | 175 |
| 6.3 | Theoretical Analysis for Sealing with Dynamic Air Current | 176 |
| 6.3.1 | Physical Model | 176 |
| 6.3.2 | Calculation | 177 |
| | References. | 179 |
| 7 | Design Points for Negative Pressure Isolation Ward | 181 |
| 7.1 | Classification | 181 |
| 7.1.1 | Classification of Infectious Diseases | 181 |
| 7.1.2 | Classification of Isolation Wards | 182 |
| 7.2 | Layout Plan | 184 |
| 7.2.1 | Environment | 184 |
| 7.2.2 | Partition | 184 |
| 7.3 | Isolation Ward | 186 |
| 7.3.1 | Ward. | 186 |
| 7.3.2 | Accessory Rooms | 188 |
| 7.3.3 | People Flow and Goods Flow. | 189 |
| 7.4 | Clean Air Conditioner | 191 |
| 7.4.1 | Particularity of Cleaning Air Conditioner for Isolation Ward. | 191 |
| 7.4.2 | Specific Requirement | 192 |
| 7.5 | Positioning Arrangement of Air Openings | 194 |
| 7.5.1 | Arrangement for Single Bed | 194 |
| 7.5.2 | Arrangement for Multiple Beds. | 195 |
| 7.5.3 | Arrangement of Air Openings in Buffer Room. | 196 |

- 7.6 Determination of Pressure Difference and Differential Pressure
 - Flow Rate. 199
 - 7.6.1 Pressure Difference 199
 - 7.6.2 Differential Pressure Flow Rate. 200
 - 7.6.3 Expression of Pressure Difference. 203
- 7.7 Design Case 210
 - 7.7.1 Self-circulation System with Fan Coil Unit. 210
 - 7.7.2 Air Supply Outlet and Fan System 211
 - 7.7.3 Air Supply Outlet and Indoor Self-circulation Fan System 211
 - 7.7.4 Layout Plan for an Isolation Ward as an Example 213
 - 7.7.5 Design Parameters. 216
- References. 216



<http://www.springer.com/978-981-10-2922-6>

Dynamic Isolation Technologies in Negative Pressure
Isolation Wards

Xu, Z.; Zhou, B.

2017, X, 216 p. 154 illus., 20 illus. in color., Hardcover

ISBN: 978-981-10-2922-6